

**PERFORMANCE BENEFITS:**

- Contains a proprietary blend of buffers, chelants, and odorless reducing agents to promote the dissolution of metal deposits.
- Superior results in the removal of metals, metallic clays and calcium carbonate scale, especially when compared to generic citric and hydrochloric acid solutions.
- Highly buffered to resist pH changes during the cleaning process.
- Compatible with polyamide and cellulose acetate membranes.
- Suitable for use with other Avista cleaners.

RoClean P903 is a low pH powdered cleaner designed to remove iron, manganese, and aluminum deposits from spiral wound polyamide and cellulose acetate elements. This formulation is temperature compensated to ensure that the cleaning solution remains in the effective pH range regardless of variations in solution temperature.

RoClean P903 has been certified by NSF International under NSF/ANSI Standard 60 for use as an off-line cleaner in drinking water systems.

**INSTRUCTIONS FOR USE**
**Storage**

Below is a summary of the RoClean P903 cleaning guidelines. For detailed procedures, please consult the Avista technical bulletin entitled "Cleaning of Spiral Wound Membrane Systems."

1. Fill the cleaning tank to the desired volume with RO permeate or deionized water. Heat the solution to the maximum acceptable temperature (see membrane manufacturer guidelines), as this will dramatically increase cleaning efficiency. Add sufficient RoClean P903 to create a 2% wt/wt solution if the fouling is moderate to severe or a 1% if the fouling is mild. Recirculate the solution through the cleaning tank to ensure adequate mixing.
2. Run the cleaning solution through each RO system stage, one at a time, for a minimum of 60 minutes at the flow rate recommended by the membrane manufacturer. If that rate is not known, use the guidelines:

Element Diameter, inches	Flow Rate per Vessel, gpm (m3/hr)
4	10 (2.4)
8	40 (9.0)

3. If the membranes are heavily fouled and the recirculated cleaning solution becomes discolored or turbid, discard as much as 15% of the solution volume. Heavily fouled elements may also benefit from a soaking period (up to 8 hours).
4. Monitor the pH of the solution during the cleaning process. If the pH remains in the desired range and the solution is not turbid, it may be used to clean subsequent stages. In the unlikely event that the pH rises, prepare a new batch and repeat steps 1-4.
5. When cleaning is complete, rinse the membranes by flushing RO permeate through each pressure vessel. The system can then be returned to service.

Please consult your sales representative for further technical or logistical details and always review the SDS before use to ensure suitable safety precautions are followed.

**CORPORATE OFFICES**

**Avista Technologies, Inc.**  
**Global Headquarters**  
 140 Bosstick Boulevard  
 San Marcos, California 92069  
 United States  
 Tel. | +1.760.744.0536



**Avista Technologies (UK) Ltd**  
 13 Nasmyth Square, Houstoun Industrial Estate  
 Livingston, EH54 5GG  
 United Kingdom  
 Tel. | +44 (0) 131 449 6677

www.avistatech.com

**PRODUCT INFORMATION**
**Packaging and Storage**

Standard regional pack sizes are listed below. Information on drumless or bulk tanker delivery is available on request.

**SPECIFICATIONS**

Appearance: White powder

pH (2% solution): 2.5 - 3.5

PACKAGING FORMAT	AMERICAS /ASIA	EMEA
Pail	45 lb	20 kg
Carboy	90 lb	-
Drum	350 lb	-